

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants</b>								
Contaminants	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Nitrate	10	10	5.4	4.8-5.4	PPM	2021	N	Runoff from fertilizer use leaching from septic tanks, erosion of natural deposits.
Distribution Chlorine	MRDL=4	MRDLG=4	0.21	0.21-2.1	PPM	2021	N	Water additive to control microbes.
TTHM	80	NA	39.2	11.9-39.2	PPB	2021	N	By-product of drinking water chlorination.
HAA5	60	NA	31.6	9.7-31.6	PPB	2021	N	By-product of drinking water chlorination.
Radium 228	5	0	1.1	NA	PPM	2015	N	Erosion of natural deposits.

<b>Entry Point Disinfectant Residual</b>							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y / N	Sources of Contamination
Chlorine	0.4	0.4	0.40-2.5	PPM	2021	N	Water additive used to control microbes.

<b>Lead and Copper</b>							
Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Units	# of sites above AL of Total Sites	Violation Y\N	Sources of Contamination
Lead (2019)	15	0	6	PPB	0 out of 20	N	Corrosion of household plumbing
Copper (2019)	1.3	1.3	0.16	PPM	0 out of 20	N	Corrosion of household plumbing

<b>Microbial</b>					
Contaminants	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Sources of Contamination
Total Coliform Bacteria	For systems that collect < 40 samples/month More than 1 positive monthly sample For systems that collect ≥ 40 samples/month 5% of monthly samples are positive	0	0	N	Naturally present in the environment
Fecal Coliform Bacteria or E. Coli	0	0	0	N	Human & animal fecal waste